



REQUEST FOR QUOTATION

Name of Project : **Supply, Delivery, and Installation of
2 HP Air-conditioning Unit**

Approved Budget for the Contract : **P100,000.00**

Deadline for Submission : **August 17 2018**

Please quote your best quotation in line with the attached specifications. Suppliers are required to submit their valid and current Mayor's Permit, PhilGeps Registration Certificate, Income/Business Tax Return and Omnibus Sworn Statement.

Quotations may be submitted personally to the BAC Secretariat, 5th floor, PPA Corporate Bldg., Bonifacio Drive, South Harbor, Port Area, Manila or email at mlpperez@ppa.com.ph. Quotations/documents sent to any other departments or email address will not be considered.

For further information, please refer to:

The BAC Secretariat, Philippine Ports Authority
5th Floor, PPA Bldg., Bonifacio Drive
South Harbor, Port Area, Manila
Telephone/Fax No. 527-4735
954-88-00 loc. 539
PPA Website: www.ppa.com.ph

Very Truly Yours,

MARK JON S. PALOMAR
Chairperson, Bids and Awards Committee
Procurement of Goods and Consultancy Services

SPECIFICATIONS

Type	2HP Wall Mounted, Split-Type, Inverter, with Anti-rust coating
Voltage, Frequency, Phase	230V, 60Hz, 1Ph
Refrigerant	R410A
Airflow Hi/Mi/Lo	891/635/550
Indoor Noise Level Hi/Mi/Lo	45/39/33
Outdoor Noise Level Hi/Mi/Lo	57
Unit Dimension	
Indoor Unit	965x215x319 mm
Outdoor Unit	800x333x554 mm
Weight	
Indoor Unit	11.2 Net 12.7 Gross
Outdoor Unit	31 Net 33 Gross
Liquid, Gas	1/4", 1/2"
Max refrigerant pipe length	30
Max difference in level	20
Operation temperature range	17-30 degrees celcius
Ambient temperature range	18-52 degrees celcius
Applicable area (unloaded space)	23-33 sq.m.

1. Delivery and installation must be completed within three (3) days from receipt of purchase order.

2. The supplier must provide at least one (1) year warranty for the unit.