



REQUEST FOR QUOTATION
PURCHASE REQUEST NO.

Name of Project : **Upgrading of PTB Main Powerline System at Baseport Ormoc**

ABC : **Php 986,197.93**

Delivery Term : **30 Calendar Days**

May 27, 2019

Dear _____:

Greetings!

The Philippine Ports Authority PMO Western Leyte/Biliran sees the need to undertake the procurement of the above project. In this regard and as authorized in accordance with the IRR RA 9184, we are inviting you to participate in direct negotiations with the Authority.

If interested please submit your proposal not later than **June 3, 2019.**

However, the Authority reserves the right to reject your proposal should the BAC find your offer disadvantageous to the government.

Attached is the request for price quotation form containing the list of requirements, terms of reference and proposed hydrographic/topographic plan for your reference.

Your prompt and timely response to this opportunity would be highly appreciated.

Very truly yours,

KRISTINE V. DARUNDAY
BAC Chairman

6/24/19

Acknowledge receipt:

Authorize representative/Date



Philippine Ports Authority
PORT MANAGEMENT OFFICE OF WESTERN LEYTE/ BILIRAN
 Blk 13 Lot 2 - Doña Feliza Mejia Subdivision, D. Veloso Avenue, Cogon, Ormoc City
 Tel # 053 561 4663

Date : **MAY 24, 2019**
 PR No. : **ORM - 1857 - 19**

 (Supplier)

 (Address)

REQUEST FOR PRICE QUOTATION

Sir / Madam :

Please quote your lowest price on the items(s) listed below. Do not quote more than one price on any single item, otherwise same shall be cancelled. Seal and return this form with your quotation on _____.

KRISTINE V. DARUNDAY
 BAC Chairperson
 5/24/19

PR Item#	Qty	Unit	NAME OF MATERIALS	Unit Price
1	1.00	pcs	Anchor, Expanding, 10,000 Lbs., 8 Way, Galvanized Steel	
2	16.00	pcs	Bolt, Carriage 3/8" x 4-1/2"	
3	12.00	pcs	Bolt, Double Arming, 5/8" x 22"	
4	3.00	pcs	Bolt, Double Arming, 5/8" x 24"	
5	12.00	pcs	Bolt, Oval Eye, 5/8" x 12"	
6	2.00	pcs	Bolt, Oval Eye, 5/8" x 18"	
7	1.00	pcs	Bolt, Thimble Eye, 5/8" x 9" Angle Type	
8	4.00	pcs	Bolt, Machine, 1/2" x 6"	
9	6.00	pcs	Bolt, Machine, 5/8" x 8"	
10	1.00	pcs	Bolt, Machine, 5/8" x 12"	
11	10.00	pcs	Brace, Angle, 1-1/2" x 1-1/2" x 3/16", 60" Span	
12	1.00	pcs	Clamp, Anchor Rod Bonding, Single Eye	
13	12.00	pcs	Clamp, Loop Deadend #6 to #2/0 ACSR	
14	24.00	pcs	Clamp, Deadend Strain #2 - #4/0 ACSR	
15	2.00	pcs	Clamp, Guy Straight, 3 Bolt Heavy Duty Steel	
16	6.00	pcs	Clevis, Secondary Swinging w/o Spool	
17	2.00	pcs	Shackle, Anchor, Forged Steel, Galvanized	
18	450.00	meters	Conductor Bare, ACSR, #1/0, AWG. 6/1 (MTS)	
19	6.00	pcs	Insulator, Spool, 3" ANSI Class 53-4	
20	20.00	pcs	Nut, Eye, 5/8" Conventional	
21	24.00	pcs	Insulator, Suspension, 15KV Polymer	
22	6.00	pcs	Insulator, Post Type, With 7" Stud	
23	16.00	pcs	Nut, Lock, Mf Type, 3/8"	
24	59.00	pcs	Nut, Lock, Mf Type, 5/8"	
25	4.00	pcs	Nut, Lock, Mf Type, 1/2"	
26	1.00	pcs	Rod, Anchor, Threaded, Single Eye, 5/8" x 7"	
27	9.00	pcs	Lag, Screw, 1/2" x 4"	
28	2.00	pcs	Pole Clamp RI Type 7-8 6Mm (Jfi Consignment)	
29	67.00	pcs	Washer, Square, Flat 2-1/4" x 2-1/4" x 3/16"	
30	21.00	ft	Wire, Tie, Aluminum Alloy, Soft, #4 AWG	
31	4.00	pcs	Washer, Round, 1-3/8" Diameter x 12 Ga.	
32	10.00	ft	Wire, Tape, Armor, Al. Alloy, 0.5" x 0.3"	
33	50.00	ft	Wire, Guy, Steel, 3/8" - 7 Strand	
34	10.00	pcs	Crossarm, Steel, 8"	
35	3.00	pcs	Clamp, Hot Line, #2 - #4/0 ACSR Main to #2 - #4/0	
36	2.00	pcs	Treated Pole 40/4 yellow pines	
37	1.00	pcs	EDMI MK6N CLASS 0.5S 3 Phase Meter, Electronic Revenue Meter "Genius Series"	
38	2.00	pcs	Transformer, Current, 600V Outdoor, 200:5 Ratio - Type: Distribution & Donut Type, Outdoor - Ratio (CTR): 200:5 - Voltage & Insulation: 600V, 110kV BIL, - Accuracy Class: 2.05-0.3% - Burden: 0.2-0.5Ω, - Any Brand accepted but subject for testing and evaluation for approval of Engineering Division	
39	2.00	pcs	Transformer Pole Mounting Bracket 1 Phase	
40	1.00	Lot	Installation of Main Powerline	

41	9.00	pcs	Cutout and Arrester Combination
42	3.00	pcs	Distribution Transformer 1. 50 kVA, Distribution Type, Additive, Conventional 2. Cooling Method: Self-cooled (OA or ONAN) 3. Core loss≤ 135W, Copper Loss≤ 500W 4. Impedance: 2%, Tolerance: ±10% 5. With No-Load Tap Changer: one (1) - 2 ½ % tap above and three (3) - 2 ½ taps below rated primary voltage. Tap 2 shall be the nominal tap. 6. Primary Voltage: 7,620/132100Y Volts, Double Bushing 7. Secondary Voltage: 120/240 Volts, Triple Bushing 8. Average Sound level: ≤ 48 Decibels 9. With full specifications located in the Nameplate 10. Serial number, owner and kVA rating should be painted (GRAY Body Painted, with 2.5 inch Bold Black Text Color) on the DT body. Labels should be located directly below the 3 secondary bushings.
43	1.00	pcs	Meter Box
44	1.00	pcs	Current Transformer Box
45	25.00	meters	Royal Cord, #12 AWG/4 cores
46	85.00	meters	THHN Stranded Wire, 150 mm²
47	15.00	meters	Ground wire THHN stranded wire 30mm
48	1.00	pcs	Grounding rod ,copper weld 3/4 x 10 ft
49	1.00	pcs	Ground clamp
50	2.00	pcs	Service Entrance Cap 100mm
51	2.00	length	RSC Pipe #4"
52	2.00	pcs	RSC long Elbow #4"
53	4.00	pcs	Crossarm, Steel, 10'
54	9.00	bags	Portland Cement, 40 kgs.
55	1.00	cu.m	Washed Sand
56	1.00	cu.m	Crushed Gravel
57	2.00	cu.m	Water
58	111.00	kgs	Deformed Bar, Grade 40
59	3.00	kgs	G.I. Tie Wire #16
60	167.00	bd. Ft	Coco Lumber
61	6.00	kgs	CWN assorted
62	2.00	sheets	Plywood, ordinary 1/2 thk
XX			
Upgrading of PTB Main Powerline System at Baseport Ormoc			

CANVASSER

NAME & SIGNATURE OF SUPPLIER

TIN No.