


PROJECT TITLE: PROVISION OF 3 UNITS CURRENT TRANSFORMER AND 3 UNITS POTENTIAL TRANSFORMER AT METER ENTRANCE, REPAIR OF WATERLINE AND REPAIR OF PAVEMENT BESIDE CHB FENCE AND TMO BUILDING					SHEET NO. 1 2
PORT OF SINDANGAN, SINDANGAN, ZAMBOANGA DEL NORTE					
CADD BY:	CHECKED BY:	REVIEWED BY:	RECOMMENDING APPROVAL BY:	APPROVED BY:	
<i>[Signature]</i> ABDUL RAFFEY H. PADDAM DRAFTSMAN (OUTSOURCED)	<i>[Signature]</i> ENGR. BRYAN E. BALLON SENIOR ENGINEER - A	<i>[Signature]</i> ENGR. DIOSDADO U. ARANAYDO PRINCIPAL ENGINEER - A	<i>[Signature]</i> ENGR. ABDURASAD S. HASAN ESQ. MANAGER	<i>[Signature]</i> ARCIDI S. JUMAANI PORT MANAGER	



DATE: NOV. 5, 2019



LEGEND:

-  14.05M X 1.40M PAVEMENT CONCRETING (PROPOSED)
-  EXISTING 0.25 X 0.30 CONC. CURB
-  126.00 LM 1/2 HDPE SDR-11 WATER PIPE LINE (PROPOSED)
-  2.10M X 1.20M PWD RAMP (PROPOSED)
-  PROPOSED OF 3-UNITS CE 10/5:5A & 3-UNITS PT 70:1, 15V (OUTDOOR TYPE)
-  100mm² THHN STRANDED WIRE

GENERAL PLAN
SCALE NTS

 PHILIPPINE PORTS AUTHORITY PMO ZAMBOANGA DEL NORTE	PROJECT TITLE: PROVISION OF 3 UNITS CURRENT TRANSFORMER AND 3 UNITS POTENTIAL TRANSFORMER AT METER ENTRANCE, REPAIR OF WATERLINE AND REPAIR OF PAVEMENT BESIDE CHB FENCE AND TMO BUILDING PORT OF SINDANGAN, SINDANGAN, ZAMBOANGA DEL NORTE					SHEET NO. 2 2 DATE: NOV. 5, 2019
	CADD BY:  ABDUL RAEF H. PADDAM DRAFTSMAN (OUTSOURCED)	CHECKED BY:  ENGR. BRYAN E. BALLON SENIOR ENGINEER - A	REVIEWED BY:  ENGR. DIOSDADO U. ARANAYDO PRINCIPAL ENGINEER A	RECOMMENDING APPROVAL BY:  ENGR. ABDURASAD S. HASAN ESD MANAGER	APPROVED BY:  ARCIDLS. JUMAANI PORT MANAGER	